



Zamboanga City Electric Cooperative, Inc.
(ZAMCELCO)
MCLL Highway, Putik, Zamboanga City

The Zamboanga City Electric Cooperative, Inc. (ZAMCELCO) at Brgy. Putik, this city, through its Bids and Awards Committee (BAC), Invites all interested parties to apply for eligibility and to bid for the following goods:

ITEM NO.	QTY	DESCRIPTION	ABC (Unit Cost)	SOURCE OF FUND	AMOUNT OF BIDDING DOCUMENTS
1	5000 units	Electronic Kilowattour Meter with Meter Round Base, Meter Base Plastic Clear cover, Socket type and self contained.	1,700.00	RFSC	10,000.00
		<p align="center">Technical Specifications</p> <p>1. Single phase, 2-wire, 240V, Current Capacity: Min: Zero (0) Amp., Max: 200Amp.</p> <p>2. 60Hz, Outdoor Type, Operates at voltage range from -25% to +20% of 240V</p> <p>3. Accuracy: Class 0.5, Test Ampere: TA 15/30Amp., Meter base capable of 200Amp. Rating</p> <p>4. Temperature: -40°C to +70°C, Humidity: 0% to 95% relative humidity, non-condensing</p> <p>5. Internal Meter loss : Low meter loss design (ERC Meter loss test result must be presented)</p> <p>6. With Instantaneous Power display and Energy flow arrow display</p> <p>7. With activated pulse indicator</p> <p>8. With 6 character LCD display (readable) display size equivalent to 3/4 inch</p> <p>9. With back-up battery, minimum of five (05) years battery lifespan when not energized</p> <p>10. Built-in Transient/Surge Protection (Manufacturers design and test result must be indicated and presented)</p> <p>11. Meter Outer Cover must be made of polycarbonate plastic.</p> <p>12. Meter Back Cover must be made of Bakelite Material or Good Quality Hard Plastic material.</p> <p>13. Meter Base must be made of Bakelite Material or Good Quality Hard plastic material (Preferably JFI meter base).</p> <p>14. Meter Terminals must made of Copper material.</p> <p>15. Meter Base Terminal: Four (04) Spring loaded terminal Jaw (should be Copper Material), 1" Hub diameter.</p> <p>16. Meter base plastic Clear Cover must be made of polycarbonate plastic or good quality clear plastic cover.</p> <p>17. Slip Lock Type, Sealing ring</p> <p>18. With ERC seal, Sticker and ERC Certificate of Approval for revenue metering</p> <p>19. Meets ANSI/IEC Standards, Warranty: Minimum of 01 (one) year</p> <p>20. The meter should have the sticker company name "ZAMCELCO" visible in front of the meter.</p> <p align="center">***Nothing Follows***</p>			

The complete schedule of activities is as follows:

BAC ACTIVITIES	SCHEDULE
Publication of Invitation to Bid	Friday, June 09, 2017 and Tuesday, June 13, 2017
Deadline for the submission of Letter of Intent (LOI)	Saturday, June 17, 2017 @ 11:00 a.m
Deadline for the Submission of Pre-qualification Requirements.	Tuesday, June 20, 2017 @ 5:00 p.m.
Start of Issuance of Bidding Documents	Saturday, June 24, 2017
Pre-Bid Conference will be held at Board Room, ZAMCELCO Compound, Brgy. Putik, Zamboanga City	Friday, June 30, 2017 @ 2:00 p.m.
Deadline for the Submission of Bidding Documents and opening of Bids, at Board Room, ZAMCELCO Compound, Brgy. Putik, Zamboanga City	Wednesday, July 12, 2017 @ 2:00 p.m.

Notes:

1. Failure to submit the Letter of Intent (LOI) will not be allowed to participate in the bidding.
2. The Bid documents may be acquired by interested bidders upon payment of a non-refundable fee.
3. A (2%) bidder's bond in the form of cash, cashier's/manager's check, Bank draft and (2.5%) for Bank guarantee is mandatorily required.
4. Please be advised that only those who bought bidding documents will be allowed to ask questions during the Pre-Bid Conference.
5. ZAMCELCO reserves the right to reject any or all bids, waive any formality or technicality therein, accept any bid deemed most advantageous to ZAMCELCO, or annul the bidding process and not award the contract at any time prior to contract award without incurring any liability to any bidder or party. Further, ZAMCELCO assumes no obligation to compensate any bidder or party for any loss or expense incurred in the preparation of the bid or participation in the bidding process.
6. For further information, please refer to:

The BAC Chairman

ICT/CORPLAN Department
ZAMCELCO Compound, MCLL Highway, Brgy. Putik,
Zamboanga City
Email Address: zamcelco@yahoo.com
TEL NO. (062) 991-2117, 993-2873 to 75.

MR. ERIC M. BUCOY

BAC Secretary

ENGR. FREDERIX R. BACO

BAC Chairman