

NEGROS ORIENTAL II ELECTRIC COOPERATIVE

BIDS AND AWARD COMMITTEE

SUPPLEMENTAL BID BULLETIN NO. 01-2019

SUBJECT : Supply and Delivery of Steel Poles

This Supplemental Bulletin is being issued to amend the requirement relative to the Procurement of Supply and Delivery of Steel Poles of various length. The Noreco II Bids and Awards Committee hereby decides to revise, amend, delete and/or adopt the following provisions of the bidding documents relative to the above-mentioned procurement:

A. CHANGES IN *SCHEDULE OF REQUIREMENT*

FROM	TO
Steel Poles Length and Requirement 30-footer ----- 300 pcs. 35-footer ----- 200 pcs. 40-footer ----- 150 pcs. 50-footer ----- 30 pcs	Steel Poles Length and Requirement 30-footer ----- 300 pcs. 35-footer ----- 200 pcs. 40-footer ----- 150 pcs. 45-footer ----- 100 pcs. 50-footer ----- 18 pcs.


B. CHANGES IN *TECHNICAL SPECIFICATION*

FROM							
POLE HEIGHT (FT)	STRENGTH	THICKNESS (mm)	BUTT DIAMETER (mm)	TIP DIAMETER (mm)	DESIGN LOAD (KG)	YIELD STRESS (MPA)	ZINC COATING (microns)
30	3700	3	226	127	500	345	86
35	3700	3	248	127	500	345	86
40	3700	3	317	127	500	345	86
TO							
POLE HEIGHT (FT)	STRENGTH	THICKNESS (mm)	BUTT DIAMETER (mm)	TIP DIAMETER (mm)	DESIGN LOAD (KG)	YIELD STRESS (MPA)	ZINC COATING (microns)
30	3700	3	226	127	500	345	86
35	3700	3	248	127	500	345	86
40	3700	3	317	127	500	345	86
45		4			750		86
50		4			1200		86

NOTES: 45 footer and 50 footer Pole are of Two-section poles.

C. NO CHANGES IN THE ABC (P16,000,000.00)

Noted by : 
Atty. Fe Marie D. Tagle
General Manager


Engr. Joseph B. Macalua
BAC Chairman (Procurement of Steel poles)