



LA UNION ELECTRIC COOPERATIVE, INC.
 STA. RITA EAST, ARINGAY 2503, LA UNION

TEL NOS: (072) 714-0238 / (072) 607-9411
 (072) 523-3106 / 523-3107
 HOTLINE: (0917) 564-2606 / (0917) 108-7661
 FAX NO. (072) 714-0553
 Email: lueico.opp@yahoo.com

SUPPLEMENTAL BID BULLETIN No. 001-2020

1. Notice to Bidders

Bidders are hereby notified of the amendments, revisions, modifications and clarifications to the Bidding Documents earlier made available to Bidders relating to the Invitation to apply for eligibility and to Bid Lots 1 to 9.

Any provision of previous issuances by the BAC which are inconsistent with any of the provisions of this supplemental Bulletin No. 001-2020 shall be deemed hereby superseded.


2. The following are the amendments:

LOT	DESCRIPTION	ORIGINAL	AMENDED
LOT 1	15 KV PROTECTION EQUIPMENT & FEEDER METERING	Circuit Breaker, Type Tested, Modular, Vacuum, GIS, 1250A, Medium Voltage Switch Gear MVSG with Complete Accessories, <u>Draw Out Type</u> SCADA Ready and Termination Kit (for main secondary breaker, indoor)	Circuit Breaker, Type Tested, Modular, Vacuum, GIS, 1250A, Medium Voltage Switch Gear MVSG with Complete Accessories, SCADA Ready and Termination Kit (for main secondary breaker, indoor)
LOT 1	15 KV PROTECTION EQUIPMENT & FEEDER METERING	Circuit Breaker, Type Tested, Modular, Vacuum, <u>GIS</u> , 630A, Medium Voltage Switch Gear MVSG with Complete Accessories, Draw Out Type SCADA Ready and Termination Kit (for 3 feeder breaker, indoor)	Circuit Breaker, Type Tested, Modular, Vacuum, <u>AIS</u> , 630A, Medium Voltage Switch Gear MVSG with Complete Accessories, Draw Out Type SCADA Ready and Termination Kit (for 3 feeder breaker, indoor)
LOT 1	69 KV CURRENT TRANSFORMER	ACCURACY CLASS (ANSI): <u>0.3</u>	ACCURACY CLASS (ANSI): <u>0.2</u> BURDEN : <u>5 VA</u>
LOT 3, 4, 5, 7 & 8	KWH METER, INSTRUMENT TRANSFORMER, VACUUM RECLOSER, DISTRIBUTION TRANSFORMER	BILL OF LADING (NOT INCLUDED IN THE REQUIREMENTS)	BILL OF LADING SHALL BE SUBMITTED
LOT 6C, ITEM 38	LINE MATERIALS	PIN, CROSSARM, CLAMP TYPE , 1"	FABRICATION IS ACCEPTED

3. Schedule

	ORIGINAL	AMENDED
DEADLINE OF SUBMISSION		
(Eligibility of Requirements)	January 25, 2020 (5pm)	January 27, 2020 (5pm)
CHECKING & EVALUATION		
(Eligibility of Requirements)	January 27, 2020 (10am)	January 28, 2020 (10am)
OPENING (Lot 1 & Lot 2)	January 29, 2020 (9am)	February 05, 2020 (9am)
OPENING (Lot 3 to Lot 9)	January 29, 2020 (1:30pm)	February 05, 2020 (1:30pm)

For guidance and information of all concerned.


 (Sgd.) ENGR. WINSTON C. SUBIDO
 BAC Chairman