



OCCIDENTAL MINDORO ELECTRIC COOPERATIVE, INC.

M.H. Del Pilar St., San Jose, Occidental Mindoro 5100



-0000000-

BIDS AND AWARDS COMMITTEE

-0000000-

BID BULLETIN No. 03

Series of 2020

“Supply and Delivery of Distribution Transformers and Protection Equipment”

OMEKO PAP No. BAC20-003

This Bid Bulletin No. 03, Series of 2020 is hereby issued to amend some provisions of the Bidding Documents for the Supply and Delivery of Distribution Transformers and Protection Equipment.

I. AMENDMENTS TO THE BIDDING DOCUMENTS


EDSEL P. PEDERNAL, REE
BAC Chairman


CELSO D. GARCIA, REE
BAC Vice Chairman

MEMBERS:


MARLENE C. ACOTINA


JOHN PATRICK G. LOYZAGA

SECTION	QUESTIONS AND CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE	AMENDMENTS/ CLARIFICATIONS
Invitation to Bid Provision No. 2 and ITB Clause 1.2	If the delivery of goods can extend to 60 days or 120 days?	The Committee adhere to the ITB's provision and clause that the delivery of goods shall be within Thirty (30) Calendar Days upon receipt of Notice to Proceed (NTP) and Purchase Order (PO).
ITB Clause 11.1 (a)(iii) and 11.1 (a)(iv)	The BAC Chairman raised that the ITB Clause 11.1 (a)(iii) and ITB Clause 11.1 (a)(iv) are the same.	The Committee hereby amended the ITB Clause 11.1 (a)(iii) and (iv) to BIR Certificate of Registration (BIR Form No. 2303).
ITB 11.1(a)(v)(i)	What are the months covered for the VAT payments?	The Committee hereby clarified that the proof of VAT payments for the past six months shall be covered the period from December 2019 to May 2020.
ITB Clause 11.1(a)(x)	Can the audited financial statement be submitted even it is not yet stamped received by the BIR?	In cases that the set of audited financial statements is not yet stamped “received” by the BIR, it shall be accepted together with the official receipt as proof of payment, and certification of their schedule for the stamp as proof that the bidder has submitted and applied within the period prescribed by the BIR, provided that the stamped audited financial statements shall be submitted upon request of the BAC for purposes of post-qualification requirement.


EDSEL P. PEDERNAL, REE
 BAC Chairman



CELSO D. GARCIA, REE
 BAC Vice Chairman


MEMBERS:


MARLENE C. ACOTINA



JOHN PATRICK G. LOYZAGA

SECTION	QUESTIONS AND CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE	AMENDMENTS/ CLARIFICATIONS
ITB Clause 18 and 21	Can the submission and opening of bids be extended?	Bids must be received by the OMECO BAC on or before 24 July 2020 at 1:00 PM at OMECO Multi-Purpose Hall, OMECO Main Office, M.H. Del Pilar St., Brgy. VI, San Jose, Occidental Mindoro. Opening of Bids shall be on 24 July 2020 at 2:00 PM at the address mentioned above.
ITB Clause 25	What process shall be done during the post-qualification with regards to the inspection of goods and examination of the documentary evidence of the Bidder's qualifications submitted?	Due to the uncertainties brought by the COVID-19, the post-qualification will depends on the proclamation, issuances or advisories on the travel restrictions. Thus, the Committee will inform the Lowest Calculated Bid in writing the process of the post-qualification.
Technical Specifications	Is the voltage of the transformer is 13,200 GrdY?	Voltage Ratings HV = 13,200 GrdY/7,620V ; LV = 120/240V % Impedance (%Z) = 2.0, ±10% Tolerance
	What is the tap change of the distribution transformer? Is it Tap 2 or 3?	5 Taps and the normal tap is Tap 3, Tap 5 shall be assigned as the highest tap.
	What is the preferred country of origin?	For distribution transformers any country is accepted, while the cut-out and arrester combination shall be originated from US, Mexico or Europe.
	Can the Prospective Bidders submit the notarized warranty certificate for distribution transformers be combined with the notarized warranty certificate for cut-out and arrester combination?	The Bidders must submit a separate notarized warranty certificate for distribution transformers, and cut-out and arrester combination.
	What is the preferred type for cut-out and arrester? Is it Polymer or Porcelain?	Both are accepted.
	What is the preferred specifications for fuse links? Is it solid button head or removable button head?	Both are accepted.


EDSEL R. FEDERNAL, REE
 BAC Chairman


CELSO D. GARCIA, REE
 BAC Vice Chairman

MEMBERS:



MARLENE C. ACOTINA

JOHN PATRICK G. LOXAGA

SECTION	QUESTIONS AND CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE	AMENDMENTS/ CLARIFICATIONS
Technical Specifications	Is the transformer is copper to copper?	Yes.
Bidding Forms and Official Bid Form	Request for a word file or excel file of the forms.	The word file of the bidding forms and the excel file of the official bid form will be sending to the official email address of the Bidders, provided that the items and the bill of quantities shall be in protected view, provided further that Bidders shall pay the applicable fee for the Bidding Documents not later than the submission of bids.
GCC Clause 9.1	Payments shall be made only upon approval by the HoPE to the effect that the Goods have been rendered or delivered in accordance with the terms of this Contract and have been duly inspected and accepted. Ten percent (10%) of the amount of each payment shall be retained by OMECO to cover the Supplier's warranty obligations under this Contract as described in GCC Clause 15.	One-time payment shall be made upon full delivery to the effect that the Goods have been rendered or delivered in accordance with the terms of this Contract and have been duly inspected and accepted.
GCC Clause 9.2	Payment shall be made upon full delivery and final acceptance of the Goods.	This section is hereby deleted.

(Intentionally Left Blank)


EDSEL P. PEDERNAL, REE
 BAC Chairman


CELSO D. GARCIA, REE
 BAC Vice Chairman

MEMBERS:


MARLENE C. ACOTINA


JOHN PATRICK G. LOZAGA

SECTION	QUESTIONS AND CLARIFICATIONS RAISED DURING THE PRE-BID CONFERENCE	AMENDMENTS/ CLARIFICATIONS
GCC Clause 15.3.	<p>In order to assure that manufacturing defects shall be corrected by the Supplier, a warranty shall be required from the Supplier for a minimum period specified in the Technical Specifications. The obligation for the warranty shall be covered by, at the Supplier's option, either retention money in an amount equivalent to at least one percent (1%) of the total Contract Price. The said amounts shall only be released after the lapse of the warranty period specified in the Technical Specifications; provided, however, that the Supplies delivered are free from patent and latent defects and all the conditions imposed under this Contract have been fully met.</p>	<p>In order to assure that manufacturing defects shall be corrected by the Supplier, a warranty shall be required from the Supplier for a minimum period specified in the Technical Specifications. The obligation for the warranty shall be covered by, at the Supplier's option, either retention money in an amount equivalent to at least one percent (1%) or a special bank guarantee equivalent to at least one percent (1%) of the total Contract Price. The said amounts shall only be released after the lapse of the warranty period specified in the Technical Specifications; provided, however, that the Supplies delivered are free from patent and latent defects and all the conditions imposed under this Contract have been fully met.</p>

This Bid Bulletin No. 03, Series of 2020 shall form part of the Bidding Documents. Any provisions in the Bidding Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For information of all concerned.