



BATANGAS I ELECTRIC COOPERATIVE, INC.
 Km. 116 National Highway, Calaca, Batangas 4212
 Tel. No. (043) 424-0400 Local 103
 Telefax: (043) 424-0400 Local 102

SUPPLEMENTAL BID BULLETIN

DESIGN AND CONSTRUCT OF TWO-STOREY BUILDING AT BATELEC I MAIN OFFICE, CALACA, BATANGAS

Please find hereunder the following modifications in our Term of Reference in the scheduled bidding for the Design and Construct of Two-Storey Building at BATELEC I Main Office, Calaca, Batangas on November 23, 2020; 9:30 AM to wit;

REFERENCE	DESCRIPTION	FROM	TO
GCC Clause 1.17	Intended Completion Date	One Hundred Eighty (180) Calendar Days	Two Hundred Ten (210) Calendar Days
GCC Clause 12.5	Warranty against Structural Defects/Failures	As specified in the Civil Engineering Law and Building Code of the Philippines.	The warranty period for the structural defects in a building discovered within a period of 10 years from the date of final acceptance based on the structural defects stated in R.A. 9184.
Section VI. Technical Specification	Concrete Works No. 7 Steel reinforcing bars	The steel reinforcing bars indicated for footing, footing tie- beams, grade beams, columns, slabs, beams and other concrete member shall conform to the number, size and spacing as indicated in the drawings or schedule of steel reinforcement minimum.	The steel reinforcing bars indicated for footing, footing tie- beams, grade beams, columns, slabs, beams and other concrete member shall conform to the number, size and spacing as indicated in the drawings or schedule of steel reinforcement minimum of grade 40.
Section VII. Plans & Drawings	Architectural Drawing		 To include BATELEC I logo before "BATELEC I"

For your information and guidance.

ENGR. VICTOR A. MENDOZA, JR.
 TWG Chairman

ANASTACIA JUDITH D. GARCIA
 BAC Chairman