



BATANGAS I ELECTRIC COOPERATIVE, INC.
 Km. 116 National Highway, Calaca, Batangas 4212
 Tel. No. (043) 424-0400 Local 103
 Telefax: (043) 424-0400 Local 102

SUPPLEMENTAL BID BULLETIN

SUPPLY & DELIVERY OF 235 UNITS BRAND NEW DISTRIBUTION TRANSFORMER (10, 15, 25, 37.5, 50, 75 KVA)

Please find hereunder the following modifications in our Term of Reference in the scheduled bidding for the Supply & Delivery of 235 units Brand New Distribution Transformer (10, 15, 25, 37.5, 50, 75 KVA) on March 19, 2021; 9:30AM to wit;

| TECHNICAL SPECIFICATIONS | | FROM | TO | |
|--|---------------|---|--|----------------------------|
| NO. | PARAMETERS | | | |
| 32 | Tank | With tank cover which shall be grounded to the tank body using copper strap and should be 4 bolted type. | With tank cover which shall be grounded to the tank body using copper strap and should be: | |
| | | | Rating | Bolted Type Locking |
| | | | 10 to 25 KVA | Minimum of 4 |
| | | | 37.5 to 75 KVA | Minimum of 6 |
| 33 | Tank Markings | KVA Rating, BATELEC I and PCB FREE markings must be painted in black color for about 3 inches height. (Numerals and Letters Combination). | KVA Rating, BATELEC I and PCB FREE markings must be painted in black color. Text height should be: | |
| | | | KVA Rating | 5 inches |
| | | | BATELEC I | 3 inches |
| | | | PCB FREE | |
| | | | Others | |
| 10 (5 inches in font/text height) BATELEC I PCB FREE AMDT 7620V/13200VY-120V/240V | | (3 inches in font/text height) | | |

For your information and guidance.


ENGR. RYAN MALIGAYA
 TWG Chairman


ENGR. NILO G. BAYLOSIS
 BAC Chairman