PANGASINAN I ELECTRIC COOPERATIVE (PANELCO I)



San Jose Bani 2407 Pangasinan

CWDO No. 63-928-502-7969 Telefax No. 63-75-551-5564

E-mail: panelco_one@yahoo.com Website:www.panelcoi.com.ph

BIDS AND AWARDS COMMITTEE SUPPLEMENTAL BID BULLETIN NO. 2021-004

LINE REQUIREMENTS FOR EXTENSION/REHABILITATION MATERIALS (CAPEX)

This Supplemental Bid Bulletin No. 2021-004 dated August 19, 2021 is being issued to clarify, modify, or amend items in the Bidding Documents.

TECHNICAL SPECIFICATIONS

The following items are hereby revised/amended:

1. LOT 1-A Supply and Delivery of Concrete Poles

CONCRETE POLES	
From	То
 Pole, Concrete, 50', Class 3, 1600 Kgs. (Min. Load Break) 	 Pole, Concrete, 50', Class 3, 1400 Kgs. (Min. Load Break)

2. LOT 1-C Supply and Delivery of Line Hardware

LINE HARDWARE	
THHN Type - NONE	THHN Type – TW Type
Insulator, Pin Type, 23kv, Ansi 56-1 - NONE	Insulator, Pin Type, 23kv, Ansi 56-1 – PORCELAIN
Lightning Arrester, 10 KV, 8.4kv MCOV type - NONE	Lightning Arrester, 10 KV, 8.4kv MCOV type – POLYMER
Clamp, Pole Mounting Adapter Type - NONE	Clamp, Pole Mounting Adapter Type – RL
Clamp, Dead-End Strain, #336.4 MCM Type -	Clamp, Dead-End Strain, #336.4 MCM Type –
NONE	ACSR
Truss Guy For Down Guy Size - NONE	Truss Guy For Down Guy Size – 24"
Fuse Cut-Out Type - NONE	Fuse Cut-Out Type - PORCELAIN
Pin, Steel, 1 3/8" X 14", 23kv (3/4" Shank	Pin, Steel, 1 3/8" X 14", 23kv (3/4" Shank
Diameter) Thread Diameter - NONE	Diameter) Thread Diameter – 1 3/8"
Hot Line Stirrup, #4/0 Acsr, Thread Type SIZE - NONE	Hot Line Stirrup, #4/0 Acsr, Thread Type SIZE – please refer to the specifications attached hereto

This Supplemental Bid Bulletin No. 2021-004 shall form part of the bid documents. Any provisions in the Bid Documents inconsistent herewith is hereby amended, modified and superseded accordingly.

For the information and guidance of all concerned.

Very truly yours,

NORGEL O. CALIXTRO

Chairperson, Bids and Awards Committee