



# BATANGAS I ELECTRIC COOPERATIVE, INC.

Km. 116 National Highway,  
Calaca, Batangas 4212  
Telefax No. : (043) 424-0413

## Invitation to Apply for Eligibility and to Bid for Simplified Bidding

The BATANGAS I ELECTRIC COOPERATIVE, INC. (BATELEC 1) thru its Bids and Awards Committee invites eligible bidders to participate in the simplified bidding (sealed canvass) for goods/items/services as specified below:

SQ No.	Particulars	Approved Budget Cost (ABC)	Reference	
			PR No.	Date
09-22	Supply and delivery of the following:		33926	February 7, 2022
	Pole top pin, 1" thread dia., 20" long 500 pcs.	₱105,000.00		
	Fuse cut-out, 100amps, 10-15KV 50 pcs.	₱195,000.00		
	Grounding wire, galvanized 5/16 5,000 pcs.	₱125,000.00		
10-22	Supply and delivery of 2 set Pole Mounted Recloser	₱1,400,000.00	33804	February 9, 2022

### (Second Posting)

SQ No.	Particulars	Approved Budget Cost (ABC)	Reference	
			PR No.	Date
01-22	Supply & Delivery of 50 pieces Electronic kWhr-meter, FM 3S, CL 20, 120-480volts, 2wire, TA 2.5, kH 0.3 with back up battery	₱850,000.00	33800	January 10, 2022
02-22	Supply & Delivery of 100 sets Cluster Set	₱620,000.00	33840	January 13, 2022

ACTIVITIES	SCHEDULE
Advertisement/Posting of Invitation	March 3, 2022
Submission and Opening of Sealed Quotation	March 11, 2022; 10:00AM
Evaluation of Proposal/Quotation	March 11, 2022; 11:00AM

Instruction to Eligible Bidders/Suppliers:

- All interested bidders are encouraged to file an accreditation with BATELEC I. Please email at [procurement.batelec1@gmail.com](mailto:procurement.batelec1@gmail.com) for listing of requirements.
- The interested bidder may secure copy and seek further clarifications regarding the Request for Quotations (RFQs) to the authorized representative of BATELEC I and/or Procurement Section at telephone number 09176397206 local 2035, email address [procurement.batelec1@gmail.com](mailto:procurement.batelec1@gmail.com).
- Submission of sealed quotation shall be made either by mail or hand carried by the supplier or his duly authorized representative on or before March 11, 2022 addressed to:  
BATELEC I Bids and Awards Committee Secretariat  
Batangas I Electric Cooperative, Inc.  
Km 116 National Highway, Calaca, Batangas
- All interested bidder must submit signed quotation, preferably using the BATELEC I prescribed RFQ Form with complete details of information on the Terms and Conditions as contained herein:

1. Payment Schedule	
2. Delivery Period	
3. Mode of delivery	
4. Warranty	
5. VAT Registration	
6. Price Validity	
7. Scope of Works/Technical Design, Specs. (for SQ No. 10-22)	THREE PHASE POLE MOUNTED RECLOSER (PMR) Recloser Unit Vacuum Interrupter Rated Maximum Voltage 15.5 kV Rated continuous Current 800 A Interrupting Current 16 kA

Technical Design and Specification (for SQ No. 02-22)	Mechanical Operation	30,000
	Full Load Operation	30,000
	Rated BIL	110 kV
	Recloser Controller	
60694	International Standards	ANSI/IEC C37.60, IEC 62271-111, IEC
	AC Supply Voltage	220 V
	DC Supply Voltage	12 Vdc
	Degree of Protection	IP 65/NEMA4
	Other Accessories	
	PMR to controller cable must at least 20 meters	
	With plug n play alarm system thru PMR IO	
	Operating time after AC loss	At least 120hrs/5 days
	Load profile up to 10,000 reading for 30 items	
	Event log up to 10,000 events	
	Free software application and upgrade	
	Required Certificates	
	Manufacture Certificate	
	After sales certificate	
	Distributorship certificate	
	Technical personnel certificate	
	Note: US or European or Australian made only	
	Meter cluster box assembly, 5 meter module 4 jaws long clip, PP adaptor and cap, box, PVC conduct pipe with conductor no. 6 copper wire THW	
8. Provide sample kWh meter (for SQ No. 01-22)		

Noted by:

(Sgd)A. JUDITH DC. GARCIA, MBA  
ISD Manager

(Sgd)ENGR. JEFFREY C. VILLANUEVA  
CPD Manager/BAC Chairman

(Sgd)ENGR. ALVIN O VELASCO  
General Manager