



ISC-2023-002

INVITATION FOR SEALED CANVASS

January 26, 2023

Sealed Bids/Proposals/Quotations for the Supply and Delivery of the following item for QUEZELCO 1 shall be received by the Bids and Awards Committee until 5:00PM of January 31, 2023. The bids/proposals/quotations will be open on February 01, 2023 at 9:00AM.

Quantity	Unit	Item Description	Unit Cost (Php)	Total Amount (Php)
20,000	mtrs	Duplex Wire #6		
4,572	mtrs	Guy Wire 7 strand, 3/8 (mtrs)		
GRAND TOTAL				

Instruction to Bidder and Terms of Condition:

The following shall be included in the offer:


1. Warranty statement. The bidder obligates, guarantees and warrants that the items to be delivered is within the standards and specification set by the cooperative. Warranty shall be at least 1 year. Longer warranty period will be considered in the evaluation.
2. Brochure or any document showing the technical specifications of the materials offered.
3. Authorization from the manufacturer to Supply the goods valid for the current year.
4. The materials offered shall comply with the required specification (See attached)
5. Delivery period shall be within thirty (30) calendar days after receipt of Notice to Proceed.
6. The financial offer shall be listed on the space provided above.
7. The financial offer shall not exceed the total Approved Budget Cost of **Php 1,254,827.20**
8. The ABC is VAT inclusive and the bid price should be VAT inclusive.
9. Term of payment – 90 calendar days after complete delivery.
10. Term of Delivery – FOB Pitogo.
11. Performance Bond of 5% of contracted price shall be posted within 5 days upon receipt of notice of award.
12. Price validity - 60 calendar days
13. Penalty Clause – 1/10 of 1% (0.1%) of the cost of the unperformed portion of the contract for every day of delay)

Additional Instructions:


1. Please send your quotations thru email using the designated BAC email address **quezelco1_bac@yahoo.com.ph** and shall be addressed to "The Bids and Awards Committee".
2. The subject shall bear the word "**Bids for the Supply and Delivery of Conductors Use for Power Restoration of Typhoon Paeng**"
3. The quotation shall be password protected. Password shall be sent on the day of opening (8:00 am).

QUEZELCO 1 reserves the right to reject any or shall bids without offering any reason, waive any defect therein and accept the offer most advantageous to the cooperative.

For further inquiries you may contact our QUEZELCO 1 BAC Secretariat, Ms. Maria Teresa Caraig and Ms. Lovely Jean Baldoz at QUEZELCO 1 Brgy. Pootol, Pitogo, Quezon with mobile numbers 09688520659 and 09291775334.


RODERSAN B. PONCE
BAC – Chairman

Noted by:


VICTOR R. CADA
Acting General Manager

MATERIAL SPECIFICATIONS

CONDUCTORS

1. Any brand with physical characteristics as follows and must conform with any of the following standards;
- ASTM - American Society for Testing Materials
 - ANSI - American National Standard Institute
 - NEMA - National Electrical Manufacturer's Association
 - PNS - Philippine National Standard
 - IEC - International Electrotechnical Commission

For Bare and Insulated Conductors

Size (AWG or MCM)	STRANDS No. & Size (inches)		Overall Diameter (Inches)	DC Resistance @ 25°C (ohms/mile)	Ultimate Strength (pounds)	Insulation Thickness (mils)
	Aluminum	Steel				
6	6 x .0661	1 x .0661	0.198	3.560	1,170	45
4	6 x .0834	1 x .0834	0.250	2.240	1,830	45
2	6 x .1092	1 x .1092	0.316	1.410	2,790	45
1/0	6 x .1327	1 x .1327	0.398	0.885	4,280	60
2/0	6 x .1490	1 x .1490	0.447	0.702	5,345	60
3/0	6 x .1672	1 x .1672	0.502	0.556	6,675	60
4/0	6 x .1878	1 x .1878	0.563	0.441	8,420	60

Prepared by:



ENGR. MIKE JAY A. DE ROXAS
PDS Head

Checked by:



ENGR. GERALD P. BAUTISTA
ED Manager

