



QUEZON I ELECTRIC COOPERATIVE, INC.

Brgy. Pocol, Pitogo, Quezon

Telefax: 042-318-8156

ISC-2023-004

INVITATION FOR SEALED CANVASS

February 09, 2023

Sealed Bids/Proposals/Quotations for the Supply and Delivery of the following item for QUEZELCO 1 shall be received by the Bids and Awards Committee until 5:00PM of February 14, 2023. The bids/proposals/quotations will be open on February 15, 2023 at 9:00AM.

Quantity	Unit	Item Description	Unit Cost (Php)	Total Amount (Php)
30	pcs.	Concrete pole 40ft.,CL 3A, 1600kg (minimum load break)		
11	pcs.	Concrete pole 45ft.,CL 3A, 1600kg (minimum load break)		
6	pcs.	Concrete pole 50ft.,CL 3A, 1600kg (minimum load break)		
GRAND TOTAL				

Instruction to Bidder and Terms of Condition:

The following shall be included in the offer:

1. Warranty statement. The bidder obligates, guarantees and warrants that the items to be delivered is within the standards and specification set by the cooperative. Warranty shall be at least 1 year. Longer warranty period will be considered in the evaluation.
2. Brochure or any document showing the technical specifications of the materials offered.
3. Authorization from the manufacturer to Supply the goods valid for the current year.
4. The materials offered shall comply with the required specification (See attached)
5. Delivery period shall be within forty five (45)calendar days after receipt of Notice to Proceed.
6. The financial offer shall be listed on the space provided above.
7. The financial offer shall not exceed the total Approved Budget Cost of **Php 1,367,324.00**
8. The ABC is VAT inclusive and the bid price should be VAT inclusive.
9. Term of payment – 90 calendar days upon complete delivery.
10. Term of Delivery – FOB Pitogo.
11. Performance Bond of 5% of contracted price shall be posted within 5 days upon receipt of notice of award.
12. Price validity - 60 calendar days
13. Penalty Clause – 1/10 of 1% (0.1%)of the cost of the unperformed portion of the contract for every day of delay)

Additional Instructions:


1. Please send your quotations thru email using the designated BAC email address quezelco1_bac@yahoo.com.ph and shall be addressed to "The Bids and Awards Committee".
2. The subject shall bear the word "**Bids for the Supply and Delivery of Concrete Poles for 1st Quarter of 2023**"
3. The quotation shall be password protected. Password shall be sent on the day of opening (8:00 am).

QUEZELCO 1 reserves the right to reject any or shall bids without offering any reason, waive any defect therein and accept the offer most advantageous to the cooperative.

For further inquiries you may contact our QUEZELCO 1 BAC Secretariat, Ms. Maria Teresa Caraig and Ms. LovelyJean Baldoz at QUEZELCO 1 Brgy. Pocol, Pitogo, Quezon with mobile numbers 09688520659.


RODEKSAN B. PONCE
 BAC – Chairman

Noted by:


VICTOR R. CADA
 Acting General Manager

MATERIAL SPECIFICATIONS

CONCRETE POLE

1. Must bear the manufacturer's logo on its surface.
2. Must conform to the latest revisions of the following standards:
 - a. ASTM C105 (Specification for Ground Fire Clay as a Refractory Mortar for Laying-up Fireclay Brick)
 - b. ASTM C494 (Standard Specification for Chemical Admixtures for Concrete)
 - c. ASTM C33 or C330 (Standard Specification for Concrete Aggregates)
 - d. ASTM A615 (Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement)
 - e. ASTM A82 (Cold-Drawn Steel Wire for Concrete Reinforcement)
 - f. ASTM A416 (Uncoated Seven-Wire Stress-Relieved Strand for Prestressed Concrete)
3. Concrete poles must be circular in cross – section and must have the following technical specifications:

ONE (1) SEGMENTED POLES				
Height (ft)	Class	Min. Top Diameter (mm)	Min. Butt Diameter (mm)	Min. Break Load (kg)
35	3	201	330	1000
40	3	238	380	1000
40	3A	238	380	1600
45	3	238	440	1400
45	3A	238	440	1600
50	3	238	418	1400
50	3A	238	418	1600
55	3	238	435	1400
60	3	238	453	1400

TWO (2) SEGMENTED POLES				
Height (ft)	Class	Min. Top Diameter (mm)	Min. Butt Diameter (mm)	Min. Break Load (kg)
65	3	238	530	1600
70	3	238	560	2000
75	3	238	583	2000
80	3	238	605	2000
90	3	238	650	2400

Prepared by:


ENGR. LARRY G. ILUSTRE
PD/LCS Supervisor

Checked by:


ENGR. GERALD P. BAUTISTA
Engineering Department Manager