

CAMARINES SUR II ELECTRIC COOPERATIVE, INC. (CASURECO II)

Del Rosario, Naga City Contact #: 09175141199 - Globe 09189918512 - Smart Tel # 205-2900

SUPPLEMENTAL BID BULLETIN NO. 2023 - 09

BID FOR THE SUPPLY OF ASSORTED DISTRIBUTION LINE MATERIALS AND EQUIPMENT USED FOR GAA2020 SEP (REPLENISHMENT OF WITHDRAWN MATERIALS USED FOR SEP)

This addendum is issued to modify or amend items in the Bidding Documents. This shall form an integral part of the Bidding Documents for the above-captioned project.

1. M ode of Payment:

15% upon receipt of Notice to Proceed (NTP)

75% upon delivery

10% retention fee to be released upon expiration of the warranty

- 2. Technical Specification:
 - a. The supply of various conductors should be measured in meters.
 - The transformer winding for all kVA rating must be copper (primary winding) to copper (secondary winding).

C.

ectronic kWh meter, 10(60), single phase, bottom type, 240V, class 1	167
Cut-out (porcelain/polymer)	3
Anchor block, concrete, 8" x 4'	99
Insulator, Suspension, 6" (porcelain/polymer)	54
Bracket mounting for transformer pole (single phase)	14

For guidance and information of all concerned.

Issued this 25th day of APRIL 2023 at Del Rosario, Naga City, Philippines.

ENGR. ALEXANDER M. CRUZ, PEE Chairman, Bids and Awards Committee