



CAMARINES SUR II ELECTRIC COOPERATIVE, INC. (CASURECO II)

Del Rosario, Naga City

Contact #: 09175141199 - Globe 09189918512 - Smart Tel # 205-2900

SUPPLEMENTAL BID BULLETIN NO. 2023 - 11

BID FOR THE CONSIGNMENT OF AMORPHOUS DISTRIBUTION TRANSFORMERS (25KVA, 37.5KVA, 50KVA, AND 75KVA)

This addendum is issued to modify or amend items in the Bidding Documents. This shall form an integral part of the Bidding Documents for the above-captioned project.

1. Page 32, clause 5.4 of Section III Bid Data Sheet:
The Bidder must have completed, within two (2) years from the date of submission and receipt of bids, prior to the deadline for the submission and receipt of bids, a single contract that is similar to this Project in nature and complexity, equivalent to at least fifty percent (50%) of the ABC.
2. Mounting: Cover mounted, bolt-type cover (minimum of four bolts)
3. Load Losses of the transformers shall not exceed the values specified in hereunder table:

Amorphous Metal Core				
Rating	No-Load Losses (Watts)	Load Losses (Watts)	Total Losses	
			(Watts)	% of Rated kVA
25kVA	18	290	308	1.23
37.5kVA	30	360	390	1.04
50kVA	32	500	532	1.06
75kVA	45	650	695	0.93

For guidance and information of all concerned.

Issued this 25th day of APRIL 2023 at Del Rosario, Naga City, Philippines.


ENGR. ALEXANDER M. CRUZ, PEE
Chairman, Bids and Awards Committee