



ISC-2023-028

INVITATION FOR SEALED CANVASS

September 14, 2023

Sealed Bids/Proposals/Quotations for the Supply and Delivery of the following item for QUEZELCO 1 shall be received by the Bids and Awards Committee until 5:00PM of September 19, 2023 . The bids/proposals/quotations will be open on September 20, 2023 at 9:00AM.

Quantity	Unit	Item Description	Unit Cost (Php)	Total Amount (Php)
30	pcs	Concrete pole 35ft., CL3, 1400kg (minimum load break)		
30	pcs	Concrete pole 40ft., CL3A, 1600kg (minimum load break)		
20	pcs	Concrete pole 50ft., CL3A, 1600kg (minimum load break)		
GRAND TOTAL				

Instruction to Bidder and Terms of Condition:

The following shall be included in the offer:

1. Warranty statement. The bidder obligates, guarantees and warrants that the items to be delivered is within the standards and specification set by the cooperative. Warranty shall be at least 1 year. Longer warranty period will be considered in the evaluation.
2. Brochure or any document showing the technical specifications of the materials offered.
3. Authorization from the manufacturer to Supply the goods valid for the current year.
4. The materials offered shall comply with the required specification (See attached)
5. Delivery period shall be within thirty (30) calendar days after receipt of Notice to Proceed.
6. The financial offer shall be listed on the space provided above.
7. The financial offer shall not exceed the total Approved Budget Cost of **Php 1,555,680.00**
8. The ABC is VAT inclusive and the bid price should be VAT inclusive.
9. Term of payment – 90 calendar days upon complete delivery.
10. Term of Delivery – FOB Pitogo.
11. Performance Bond of 5% of contracted price shall be posted within 5 days upon receipt of notice of award.
12. Price validity - 60 calendar days
13. Penalty Clause – 1/10 of 1% (0.1%) of the cost of the unperformed portion of the contract for every day of delay)


Additional Instructions:

1. Please send your quotations thru email using the designated BAC email address **quezelco1_bac@yahoo.com.ph** and shall be addressed to "The Bids and Awards Committee".
2. The subject shall bear the word "**Bids for the Supply and Delivery of Concrete Pole for Private Line 2023** "
3. The quotation shall be password protected. Password shall be sent on the day of opening (8:00 am).

QUEZELCO 1 reserves the right to reject any or all bids without offering any reason, waive any defect therein and accept the offer most advantageous to the cooperative.

For further inquiries you may contact our QUEZELCO 1 BAC Secretariat, Ms. Maria Teresa Caraig and Ms. LovelyJean Baldoz at mobile number 09688520659.

Noted by:


VICTOR R. CADA
Acting General Manager


GERALD P. BAUTISTA
BAC – Chairman

MATERIAL SPECIFICATIONS


CONCRETE POLE

1. Must bear the manufacturer's logo on its surface.
2. Must conform to the latest revisions of the following standards:
 - a. ASTM C105 (Specification for Ground Fire Clay as a Refractory Mortar for Laying-up Fireclay Brick)
 - b. ASTM C494 (Standard Specification for Chemical Admixtures for Concrete)
 - c. ASTM C33 or C330 (Standard Specification for Concrete Aggregates)
 - d. ASTM A615 (Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement)
 - e. ASTM A82 (Cold-Drawn Steel Wire for Concrete Reinforcement)
 - f. ASTM A416 (Uncoated Seven-Wire Stress-Relieved Strand for Prestressed Concrete)
3. Concrete poles must be circular in cross - section and must have the following technical specifications:


ONE (1) SEGMENTED POLES				
Height (ft)	Class	Min. Top Diameter (mm)	Min. Butt Diameter (mm)	Min. Break Load (kg)
35	3	201	330	1400
40	3	238	380	1400
40	3A	238	380	1600
45	3	238	440	1400
45	3A	238	440	1600
50	3	238	418	1400
50	3A	238	418	1600
55	3	238	435	1400
60	3	238	453	1400

TWO (2) SEGMENTED POLES				
Height (ft)	Class	Min. Top Diameter (mm)	Min. Butt Diameter (mm)	Min. Break Load (kg)
65	3	238	530	1600
70	3	238	560	2000
75	3	238	583	2000
80	3	238	605	2000
90	3	238	650	2400

Prepared by:


ENGR. LARRY G. ILUSTRE
PD/LCS Supervisor

Checked by:


ENGR. GERALD P. BAUTISTA
Engineering Department Manager

QUEZON I ELECTRIC COOPERATIVE, INC.

Brgy. Pocol, Pitogo, Quezon

Accreditation Requirements

Name of Company/Supplier/Representative: _____

Address: _____

Contact Number : _____

EMAIL ADD: _____

DOCUMENTS	
1	DTI Registration name registration or SEC Registration Certificate
2	Valid and current Mayor's Permit/Municipal License
3	Taxpayer's Identification Number,
4	BIR Value Added Tax Registration
5	Certification that the bidder is not "blacklisted" or banned from bidding by the government or any of its agencies, officers, corporation or LGU's and other private corporations or electric cooperatives
6	Compliance with EO # 398
	a.) Proof of VAT Payments for the past six months
	b.) Tax Clearance for the last two quarters
7	On-going, completed or awarded contract not yet started within the relevant period specifying the following:
	a. Name of contract
	b. Date of contract
	c. Amount of the contract and value of outstanding contracts
	d. Date of delivery
	e. End user's acceptance if completed
8	Company Profile
9	Latest Income Tax Return
10	Complete set of Audited Financial Statements, stamped "received" by the BIR or its duly accredited and authorized institutions, for the immediately preceding calendar year, showing, among others, the prospective bidder's total and current assets and liabilities
11	Articles of Incorporation, Partnership or Cooperation, whichever is applicable
12	A certification under oath from the bidders responsible officers that the bidders is free and clear of all liabilities with the government
13	Valid Registration with Philippine Contractor Accreditation Board (PCAB) with specialization in electrical works and with at least small B size range Classification (C and D category)- for contractor only

Email Address:

quezelco1_bac@yahoo.com.ph