



ILOILO II ELECTRIC COOPERATIVE, INC. (ILECO II)

Brgy. Cau-ayan, Pototan, Iloilo
 Tel Nos. (033)529-8063, (033)529-8981
 Email add: ileco2bac@yahoo.com

SUPPLEMENTAL BID BULLETIN

Addendum No. 1

PUBLIC BIDDING

ITB NO. 2024-09: Replacement of the 10MVA to New 20MVA Power Transformer at Calinog Substation Including 69/15kV Protection and Accessories

This Addendum No. 1 is issued to clarify and/or amend certain provisions in the Bidding Documents issued for this project.

REFERENCE	AMENDMENT/INCLUSION																
Section I. Invitation to Bid	Section I. Invitation to Bid																
Lot 2: Supply of 20/25MVA, 67/13.2kV Power Transformer	Lot 2: Design, Supply, Delivery, Construction, Installation, Testing and Commissioning of 20/25MVA, 67/13.2kV Power Transformer																
Section II. Instruction To Bidders	Section II. Instruction To Bidders																
C. Preparation of Bids B. Financial Proposal (Folder 2) - Two (2) ORIGINAL TRUE COPIES and One (1) set of SOFT COPY ; a. Bid Price in the prescribed bid form i. Financial Bid Form ii. Price Schedule	C. Preparation of Bids B. Financial Proposal (Folder 2) - Two (2) ORIGINAL TRUE COPIES and One (1) set of SOFT COPY ; a. Bid Price in the prescribed bid form i. Financial Bid Form - duly signed Bid Letter indicating the total bid amount in accordance with the prescribed form ii. Duly signed and completely filled out Bill of Quantities indicating the unit and total price per item and the total amount in the prescribed Bill of Quantities Form iii. Duly signed Detailed Estimates for each items of work showing the computations in arriving at each item's unit prices used in coming up with the bid																
Section III. Bid Data Sheet	Section III. Bid Data Sheet																
ITB Clause 12.1. The deadline for submission of bids is 03 June 2024, 1:00 p.m. ITB Clause 13.1. The date and time of bid opening is 03 June 2024, 1:30 p.m.	ITB Clause 12.1. The deadline for submission of bids is 14 June 2024, 10:00 a.m. ITB Clause 13.1. The date and time of bid opening is 14 June 2024, 10:30 a.m.																
Section IX: Warranty	Section IX: Warranty																
<table border="1"> <thead> <tr> <th>Form of Warranty</th> <th>Schedule of Warranty</th> </tr> </thead> <tbody> <tr> <td>Power Transformer and other Substation Equipment including its accessories</td> <td>Two (2) years after delivery and final acceptance</td> </tr> <tr> <td>Warranty for against structural defects/ failures for building and substation structures</td> <td>Five (5) years after completion and acceptance</td> </tr> </tbody> </table>	Form of Warranty	Schedule of Warranty	Power Transformer and other Substation Equipment including its accessories	Two (2) years after delivery and final acceptance	Warranty for against structural defects/ failures for building and substation structures	Five (5) years after completion and acceptance	<table border="1"> <thead> <tr> <th>Form of Warranty</th> <th>Schedule of Warranty</th> </tr> </thead> <tbody> <tr> <td>69/15kV Protection Equipment and Power Transformer</td> <td>Two (2) years after delivery and final acceptance</td> </tr> <tr> <td>Local Materials</td> <td>Six (6) months after delivery and final acceptance</td> </tr> <tr> <td>Powerhouse house control & Switchgear room</td> <td>Five (5) years after completion and acceptance</td> </tr> <tr> <td>Warranty for against structural defects/ failures for building and substation structures</td> <td>Five (5) years after completion and acceptance</td> </tr> </tbody> </table>	Form of Warranty	Schedule of Warranty	69/15kV Protection Equipment and Power Transformer	Two (2) years after delivery and final acceptance	Local Materials	Six (6) months after delivery and final acceptance	Powerhouse house control & Switchgear room	Five (5) years after completion and acceptance	Warranty for against structural defects/ failures for building and substation structures	Five (5) years after completion and acceptance
Form of Warranty	Schedule of Warranty																
Power Transformer and other Substation Equipment including its accessories	Two (2) years after delivery and final acceptance																
Warranty for against structural defects/ failures for building and substation structures	Five (5) years after completion and acceptance																
Form of Warranty	Schedule of Warranty																
69/15kV Protection Equipment and Power Transformer	Two (2) years after delivery and final acceptance																
Local Materials	Six (6) months after delivery and final acceptance																
Powerhouse house control & Switchgear room	Five (5) years after completion and acceptance																
Warranty for against structural defects/ failures for building and substation structures	Five (5) years after completion and acceptance																

ADDITIONAL REQUIREMENTS:

Section VI. Schedule of Requirements

1. Supply of 69/15kV Protection, Control and Metering Panel

1.1. Metering, Control and Protection Panel: Indoor Type Free Standing Metal Enclosure (Factory Tested, NEMA Standard) w/ Glazed Door equipped with the following protection relay, meters and accessories (SCADA Ready):

☐- 6 pcs Three Phase Multifunction Energy Meter with Ethernet module

☐- 1 pc. Differential Protection and Control

☐- 1 pc. 69kV Multifunction, Protection and Control Relay

☐- 5 sets 15kV Multifunction, Protection and Control Relay

☐- Overcurrent/ voltage relay

☐- Control wiring and Pilot Lamp

☐- Auxiliary Relays, Terminal Lugs and Test Blocks

- Annunciators

2. Supply of 69/15 kV Protection Equipment

2.1. 60 KV, Surge Arrester, 48KV MCOV, Class 3, Station Class


2.2. 12 KV, Surge Arrester, 9.6KV MCOV, Class 3

CLARIFICATIONS:

Lot 2 must be **20/25MVA**, 67/13.2kV Power Transformer, not 15/18.75MVA. This correction applies to all sections of the bidding documents.

The herein amendment forms an integral part of the bidding documents. Correspondingly, all other provisions in the bidding documents affected by this amendment are similarly amended or modified.


This SUPPLEMENTAL/BID BULLETIN ADDENDUM No. 1 is issued this 27th day of May 2024 for guidance and information of all concerned.


ROMMIER C. CARO
BAC Chairman


MA. UNA P. PADILLA
Vice Chairman


RODYRIC L. CLAUDIO
Member

REXUS O. LESONDATO
Member


ANGEL MAE C. GALAS
Member