

NEGROS OCCIDENTAL ELECTRIC COOPERATIVE (NOCECO)

Kabankalan City, Negros Occidental

Tel. Nos. (034) 471-2229 / (034) 471-2339 / 746-9255

Email: email@noceco.ph

Fax No. (034) 471-2829 Website: www.noceco.ph

June 5, 2024

BIDS AND AWARDS COMMITTEE (BAC) BID BULLETIN No. 1 ITB NO. 2024-001

In relation to the published Invitation to Bid 2024-001, the Bids and Awards Committee resolves the issues raised during the pre-bidding conference on June 4, 2024 for the supply and delivery of following requirements:

- 1. Various size Distribution Transformer
- 2. Electronic kWh meter, bottom type
- 3. Conductor ACSR # 1/0 Insulated
- 4. Conductor ACSR # 1/0 Bare
- 5. Conductor ACSR # Duplex # 2
- 6. Various lengths, Concrete Poles
- 7. Various lengths, Steel Poles

Particulars	From	То
Electronic kWh Meter	Display: 7-digit LCD with minimum digital size 16mmx7.1mm Display on kWh, kW, Voltage, Current Push Button, Programmable display	Additional Specs: Non push button is acceptable provided energy (kWh) display must be fixed and in accordance to the minimum digit size, other parameters (KW, Voltage & current) may be cyclical or fixed displayed
Electronic kWh Meter	Country of Origin: Philippines, Thailand, US, Western Europe	Country of Origin on ERC Type Approved Certificate: Philippines, Thailand, US, Western Europe, Korea, Singapore, Taiwan
Electronic kWh Meter	Max. Load Current: 60 Ampere	Min. Load Current: 60 Amperes
Conductor, ACSR #1/0, Insulated	30 days from the receipt of Notice to Proceed*	At least 30% of the total quantity within 30 days from the receipt of Notice to Proceed, balance 60 days from the receipt of Notice to Proceed
Conductor, ACSR #1/0, Bare	30 days from the receipt of Notice to Proceed*	At least 30% of the total quantity within 30 days from the receipt of Notice to Proceed, balance 60 days from the receipt of Notice to Proceed
Conductor, Duplex#2,	Not less than 50% of the total quantity per kVA rating within the first 30 days from the receipt of Notice to Proceed and remaining balance within 60 days from the receipt of Notice to Proceed*	At least 30% total quantity within 30 days from the receipt of Notice to Proceed, balance 60 days from the receipt of Notice to Proceed
Concrete Poles, NEA Standard 45' – 50 pcs.	Height: 45 feet Class: 3 Minimum Break Load (kgs): 1400 Top Diameter (mm): 201 Bottom Diameter (mm): 345	Height: 45 feet Class: 3 Minimum Break Load (kgs): 1400 Min. Top Diameter (mm): 238 Min. Bottom Diameter (mm): 418

0 1 0 1 1151	1	
Concrete Poles, NEA	Height: 50 feet	Height: 50 feet
Standard 50' – 50 pcs.	Class: 3	Class: 3
	Minimum Break Load (kgs): 1400	Minimum Break Load (kgs): 1400
	Top Diameter (mm) : 201	Min. Top Diameter (mm) : 238
	Bottom Diameter (mm) : 310	Min. Bottom Diameter (mm): 440
Steel Poles, NEA	Delivery Period:	Delivery Period:
Standard,	Not less than 50% of the total	At least 50% of the total quantity
a. 30'-150 pcs.	quantity per length within the	within the first 30 days from the
b. 35'-150 pcs.	first 30 days from the receipt of	receipt of Notice to Proceed and
c. 40'-140 pcs.	Notice to Proceed and	remaining balance within 60 days
d. 45' - 90 pcs.	remaining balance within 60	from the receipt of Notice to
e. 50' – 50 pcs.	days from the receipt of Notice	Proceed*
f. 55' - 50 pcs.	to Proceed*	
g. 60' - 30 pcs.	(Partial Delivery)	(Partial Delivery)
Steel Pole 45'	No. of sides: 16 sides	No of sides: octagonal (8 sides)
Warranty	Not Specified	At least one (1) year from the
	350	date of delivery
Relevant period of On-	10 years	3 years
going & Completed		,
Contract		
VAT Payments	At least 6 months	Last quarter of 2023 and 1st
		quarter of 2024

This bulletin is issued to clarify, modify, or amend items in the bidding documents. Accordingly, this shall form an integral part of the said document.

For your information and guidance.

FEDERICO P. GEQUILLANA, JR. BAC Chairman