



ILOILO II ELECTRIC COOPERATIVE, INC. (ILECO II)

Brgy. Cau-ayan, Pototan, Iloilo
Tel Nos. (033)529-8063, (033)529-8981
Email add: ileco2bac@yahoo.com

SUPPLEMENTAL BID BULLETIN

Addendum No. 1

PUBLIC BIDDING


ITB NO. 2024-14: Design, Supply, Delivery, Construction, Installation, Testing and Commissioning of the New 15MVA Imbang Substation Project

This Addendum No. 1 is issued to clarify and/or amend certain provisions in the Bidding Documents issued for this project.


REFERENCE	AMENDMENT/INCLUSION
Section III. Bid Data Sheet	Section III. Bid Data Sheet
ITB Clause 12.1. The deadline for submission of bids is 25 June 2024, 9:00 a.m.	ITB Clause 12.1. The deadline for submission of bids is 4 July 2024, 1:00 p.m.
ITB Clause 13.1. The date and time of bid opening is 25 June 2024, 9:30 a.m.	ITB Clause 13.1. The date and time of bid opening is 4 July 2024, 1:30 p.m.
Section III. Bid Data Sheet	Section III. Bid Data Sheet
ITB Clause 7.1 (II) (A) (v)	ITB Clause 7.1 (II) (A) (v)
For Lot 2: f. Truck Mounted Crane (35 Tons Cap.) - 1 unit	For Lot 2: f. Truck Mounted Crane (70 Tons Cap.) - 1 unit
Section VI. Schedule of Requirements	Section VI. Schedule of Requirements
Supply of 15/18.75MVA, 67/13.2kV Power Transformer	Supply of 15/18.75MVA, 67/13.2kV Power Transformer
Primary Voltage: 67kV Delta $\pm 2 \times 2.5\%$	Primary Voltage: 67kV Delta $\pm 3 \times 2.5\%$
Section VII. Technical Specifications	Section VII. Technical Specifications
Lot 1 Item No. 1.26 - Perimeter Fence. Perimeter Fence shall be constructed of GI chain link wire fence on GI pipe frames with concrete columns, footings and 6" CHB zocalo wall	Lot 1 Item No. 1.26 - Perimeter Fence. Perimeter Fence shall be constructed of steel matting 4.5mm \emptyset (2" x 2" hole) on GI pipe frames with concrete columns, footings and 6" CHB zocalo wall
Lot 2 - Design, Supply, Delivery, Construction, Installation, Testing and Commissioning of 15/18.75MVA, 67/13.2 kV Power Transformer for Imbang Substation	Lot 2 - Design, Supply, Delivery, Construction, Installation, Testing and Commissioning of 15/18.75MVA, 67/13.2 kV Power Transformer for Imbang Substation
US, European, Taiwan Brand	US, European, Taiwan and Vietnam Brand
ADDITIONAL REQUIREMENT:	
For Lot 1, bidders should include in their substation proposal the provision of NGCP's metering facilities (CTs & PTs). The metering facilities structures and concrete footing shall be included in the contractor's proposal.	

The herein amendment forms an integral part of the bidding documents. Correspondingly, all other provisions in the bidding documents affected by this amendment are similarly amended or modified.

This SUPPLEMENTAL/BID BULLETIN ADDENDUM No. 1 is issued this 18th day of June 2024 for guidance and information of all concerned.


ROMMIER C. CARO
BAC Chairman

MA. UNA P. PADILLA
Vice Chairman


RODYRIC L. CLAUDIO
Member


REXUS O. LESONDATO
Member


ANGEL MAE C. GALAS
Member