



# NATIONAL ELECTRIFICATION ADMINISTRATION

"The 1<sup>st</sup> Performance Governance System-Institutionalized National Government Agency"  
57 NIA Road, Government Center, Diliman, Quezon City 1100



Management  
System  
ISO 9001:2015



www.tuv.com  
ID 9105082030

11 January 2023

## TECHNICAL ADVISORY NO. 01-2023

TO : ALL ELECTRIC COOPERATIVES

SUBJECT : PUTTING UP OF SIGNAGES TO ALL OBSTRUCTING  
FACILITIES AFFECTED BY DPWH ROAD WIDENING  
PROJECTS

It has been observed that there are EC-owned distribution facilities located within the widened roadway pending compensation by the Government pursuant to DOE-DPWH Joint Circular Nos. 1, 2 and 3.

With the implementation of the Department of Works and Public Highways road widening projects, a number of affected electric distribution poles of the Electric Cooperatives (ECs) have remained within the road right-of-way posing safety risk to commuters and road users.

With the pendency of the process of compensation in the relocation of affected distribution poles, the ECs are directed to put up road safety signages on these obstructing poles to minimized or prevent risk to road users.

The ECs shall install safety signages, reflectorized stickers, or reflective paint clearly visible under headlight illumination.

The signages shall be installed at a minimum height of one (1) meter, and should be at least 450mm x 450 mm.

For your information, guidance and strict compliance.

  
OMAR M. MAYO

Deputy Administrator for Technical Services